

# Danish Indoor Climate Labelling

Certificate no. 009



Danish Indoor Climate Labelling hereby certifies that the product group:

**Knauf walls and steel building systems (untreated Knauf plasterboard)**

**Knauf A/S**  
Kløvermarksvej 6  
9500 Hobro  
Denmark

has been approved and awarded a labelling license

The labelling license is valid through:

30 May 2026

Danish Indoor Climate Labelling

This certificate is subject to annual renewal according to the procedures of Danish Indoor Climate Labelling.  
Danish Indoor Climate Labelling may withdraw the rights to use this certificate in case the manufacturer does not meet the requirements.

# Danish Indoor Climate Labelling

Certificate no. 009

Labelling license holder:

**Knauf A/S**

Kirkebjerg Parkvej 9-11E

DK-2605 Brøndby

Denmark

*Product group*

*Testing and labelling criteria*

*Date of first issue of license*

*Tested product(s)*

*Evaluation of product group*

**Knauf walls and steel building systems (untreated Knauf plasterboard)**

General labelling criteria, 7th edition, 2021

Wall and Ceiling systems, 5th edition 2018

1 May 1995

Tectopanel G1

**EMISSION CLASS 1**

The labelling license covers products considered to be identical with the tested product regarding emission and particle characteristics as specified by the labelling criteria. For a full list of products covered by the labelling license, see Appendix.

The emission and particle classes were determined based on the following measured values:

Measured values after 28 days		
TVOC <sub>28</sub>	0.01	mg/m <sup>3</sup>
Formaldehyde <sub>28</sub>	< 0.005	mg/m <sup>3</sup>

  

Sensory evaluation		
Time-value	10	days

## Labelling license basis

The tested product(s) shows compliance with the DICL criteria for the present product group:

Emission measured after 3 days			
TVOC	≤	10	mg/m <sup>3</sup>
EU CARC 1A and 1B	≤	0.01	mg/m <sup>3</sup>
Emission measured after 28 days			
Sum of TVOC and SVOC with LCI	≤	1.0	mg/m <sup>3</sup>
EU CARC 1A and 1B	≤	0.001	mg/m <sup>3</sup>
R-value	≤	1	
Sensory evaluation			
Time-value	≤	100	days

<b>Emission Class 1</b>	TVOC <sub>28</sub>	≤	0.5	mg/m <sup>3</sup>
	Formaldehyde <sub>28</sub>	≤	0.01	mg/m <sup>3</sup>
<b>Emission Class 2</b>	TVOC <sub>28</sub>	≤	1.0	mg/m <sup>3</sup>
	Formaldehyde <sub>28</sub>	≤	0.06	mg/m <sup>3</sup>
<b>Emission Class 3</b>	TVOC <sub>28</sub>	≤	1.0	mg/m <sup>3</sup>
	Formaldehyde <sub>28</sub>	≤	0.1	mg/m <sup>3</sup>

## Product information requirements

The holder of the labelling license is required to present the following product information on demand in order to avoid any adverse effects of the product on the indoor air quality in practice: product specifications, guidelines for transport, storage, assembly, cleaning and maintenance.

In the event of any discrepancies in the text arising from translation, the Danish text shall prevail.